

OPIS WYPROWADZEN LISTWY ZACISKKOWEJ ROZDZIELNICY

Projekt: SP9RQD, Robert Barwacz

	24	+	-> 12.8-13.8 VDC/40A max DO TR-1
	23	-	
	22	+	-> 12.8-13.8 VDC/40A max DO TR-2
	21	-	
	20	+	-> 12.8-13.8 VDC/40A max DO TR-3
	19	-	
	18	+	<- 12.8-13.8 VDC/40A max Z AKUMULATORA AK-1
	17	-	
	16	+	<- 12.8-13.8 VDC/40A max Z AKUMULATORA AK-2
	15	-	
	14	+	<- 14.6 VDC/40A max Z LADOWARKI AKUMULATORA
	13	-	
	12	ØF1	
	11		-> 230 VAC 50Hz DO LADOWARKI AKUMULATORA
	10	ØN	
	9	ØF1	
	8		-> 230 VAC 50Hz DO ZASILACZA SIECIOWEGO
	7	ØN	
	6	+	<- 13.8 VDC/40A max - Z ZASILACZA SIECIOWEGO
	5	-	
	4		WOLNE
	3	ØF1	
	2		<- 230 VAC 50Hz
	1	ØN	